

MUNICIPAL CORPORATION CHANDIGARH
(Medical Officer of Health)

(SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE)
(NO OBJECTION CERTIFICATE)

No. MOH/Supdt.Admn/NOC/2025/ 11408

Dated:- 28/8/25

It is certified that an inspection team headed by Sh Gulab Singh, Chief Sanitary Inspector from Office of Medical Officer of Health, Municipal Corporation Chandigarh inspected the Sri Guru Gobind Singh Collegiate School, Sector 26, Chandigarh on 07-07-2025 and mentioned in inspection report that Sri Guru Gobind Singh Collegiate School, Sector 26, Chandigarh is maintaining the hygienic sanitation condition in the premises as per the norms prescribed by the Central/State/U.T Govt. India.

The above Certificate is valid for a period of One-year w.e.f 13.05.2025 (i.e Water Sampling Date).


Medical Officer of Health
Municipal Corporation
Chandigarh

To

Sri Guru Gobind Singh Collegiate School,
Sector 26,
Chandigarh



MUNICIPAL CORPORATION CHANDIGARH

(Public Health Laboratory at Water Works Sector - 39)

TEST - REPORT

Not for legal use

Lab No. : MCPHL/25/ 1559

Date : 13.05.2025


Ref. No. : 2812	Sample Details	Date & Time
Dated : 02.05.2025		
Issued to : The Principal Sri Guru Gobind Singh Collegiate Public School, Sec-26, Chd	Collected By : Laboratory Staff	Laboratory Staff
Location : From School tap of Sri Guru Gobind Singh Collegiate Public School, Sec-26, Chd	Collection Date : 08.05.2025 at 8:10a.m	
Packing : Polypropylene and glass bottle	Received at Lab : 09:30a.m.	


Test Result (As Per BIS 10500:2012)

S.No	Examination	Quality Standard	Unit	Result
1	pH	6.5 - 8.5	---	7.76
2	Odour	Agreeable	---	Agreeable
3	Taste	Agreeable	---	Agreeable
4	Turbidity	<1	N.T.U.	0.8
5	Total Dissolved Solids	<500	mg/l	135
6	Residual Chlorine	0.2 - 0.4	mg/l	0.2
7	Total Alkalinity (as CaCO ₃)	<200	mg/l	90
8	Total Hardness (as CaCO ₃)	<200	mg/l	80
9	Chlorides (as Cl)	<250	mg/l	04
10	Free & Saline Ammonia	NIL	mg/l	NIL
11	M.P.N. of Coliform Bacilli / 100ml of water	Zero	M.P.N.	0 (Excellent)

Payment received vide receipt No. 05/2025-26/248676, dated 05.05.2025, amount Rs.-3300/-

Note: - Water sample is found " **POTABLE** "



Chemist,
M.C.P.H. Laboratory,
Chandigarh.



Sub Divisional Engineer,
M.C.P.H. Sub Division No.1,
Chandigarh.

Endst. No. MCPH/25/-----

Dated : 13.05.2025

Copy forwarded to the Medical Officer of Health Municipal Corporation, Sector -17, Chandigarh for Information please.


Chemist,
M.C.P.H. Laboratory,
Chandigarh.


Sub Divisional Engineer,
M.C.P.H. Sub Division No.1,
Chandigarh.

Remarks:-

- The results given above are related to the sample as collected and tested in lab.
- The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- The test report can't be used for any publicity or legal purpose.

----- End of Report -----

WATER IS LIFE, SAVE IT



DEBUG YOUR UPHOLSTERY & LIVE HYGIENICALLY

Dated: 20/06/2026

To,

**SGGS Collegiate Public School,
Sector – 25,
Chandigarh.**

Respected Madam,

It is certified that we have cleaned 13 water storage tanks and 10 on 20/06/2026 and make it bacteria free at the time of cleaning. The details of cleaning are as follows:

S. No.	Type	No. of Tanks
1.	PVC	10
2.	RCC	3
3.	Water Cooler	10

All the following seven steps have been taken to clean it hygienically:

1. **External Washing & Dewatering:** In the First Step of External Washing we wash Manhole and surroundings of outer of tank are cleaned off dirt and Dewatering of the Water Tank.
2. **Sludge Removal:** In the Second Step Sludge is removed with the help of sludge pumps
3. **Algae Removal:** In the Third Step algae, calcinations etc are removed from the walls with specially designed machine.
4. **Internal Washing:** In the Fourth Step walls and ceiling are washed through pressure jet cleaners.
5. **Anti-Bacterial Treatment:** In the Fifth Step walls and ceiling are sterilized with special Anti-Bacterial Solution for making it bacteria free.